

Unit Ventilator Data
Classroom Ventilation Program

Changes to original plan
Vertical Unit Ventilators

02-Jan-23

Room No.	Use	Room Area		Unit Ventilator							Top Plenum	Back/Side Plenum	Top Shroud	Duct Conn.		Notes	
				Type	Make	Model	BTUH	GPM	°F	Pipe Conn.				Hinge	Side		Size
Blundell																	
10101	Classroom	76.20		Horizontal	Daikin	UAVV9H13	75,000	3.75	180-140	Left						h abcde	
10103	VP Office	12.19	55.24	Vertical	Apollo	VUV-1200	10,000	0.50	180-140	Right	Right	N/A	Back	63	Top	k f	
10104	P Office	15.48															
10106	Admin Office	27.57															
10107	Classroom	76.17															
10109	Classroom	75.77		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Left						abcde	
10110	Classroom	75.77		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Left							abcde
10111	Classroom	84.30		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Left							abcde
10112	Classroom	84.32		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Left							abcde
10113	Multipurpose	76.17		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Left							abcde
10121	Classroom	76.17		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Right							abcde
10124	Staff Room	55.72		Horizontal	Daikin	UAVV9H10	45,000	2.25	180-140	Left							abcde
10128	Resource	48.87		Horizontal	Daikin	UAVV9H10	45,000	2.25	180-140	Left							abcde
10129	Library	136.49	147.71	Vertical	Apollo	VUV-1600	35,000	1.75	180-140	Right	Right	860	Back	N/A	Left	450X400	f
10129a	L Office	11.22															
10130	Tech Lab	76.59		Horizontal	Daikin	UAVV9H13	55,000	2.25	180-140	Left							abcde
10136	Classroom	85.31		Horizontal	Daikin	UAVV9H13	55,000	2.25	180-140	Left							abcde
10145	Classroom	93.40		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Left							abcde
10146	Resource	84.82	90.83	Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Left							abcde
10146a	R Office	6.01															
10147	Resource	40.97	177.69	Vertical	Apollo	VUV-2000	50,000	2.50	180-140	Left	Right	770	Back	N/A	Left Front	500x300 350x300	f
10148	Resource	119.61															
10149	R Office	17.11															
Cook																	
10120	Classroom	92.74		Horizontal	Daikin	UAVV9H15	58,000	2.90	180-140	Left							abcde
10122	Classroom	94.01		Horizontal	Daikin	UAVV9H15	58,000	2.90	180-140	Left							abcde
10123	Resource	54.03	62.98	Vertical	Apollo	VUV-1200	40,000	2.00	180-140	Right	Left	660	N/A	N/A	Right	300x250	f
10124	R Office	8.95															
10147	Classroom	81.76		Horizontal	Daikin	UAVV9H13	50,000	2.50	180-140	Left							abcde
10148	Classroom	79.83		Horizontal	Daikin	UAVV9H13	50,000	2.50	180-140	Right							abcde
10149	Classroom	79.23		Horizontal	Daikin	UAVV9H13	55,000	2.75	180-140	Right							abcde
10150	Classroom	80.14		Horizontal	Daikin	UAVV9H13	55,000	2.75	180-140	Left							abcde
10161	Multipurpose	100.94		Horizontal	Daikin	UAVV9H15	64,000	3.20	180-140	Left							abcde
10162	Library	147.45	194.30	Vertical	Apollo	VUV-2000	30,000	1.50	180-140	Right	Right	710	Back	N/A	Right Left	350x300 400X300	f
10162a	L Office	13.91															
10158	Resource	16.52															
10158a	R Office	16.42															
Dixon (On Hold)																	
10101	Classroom	85.23		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Left							h abcde
10102	Classroom	85.23		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Right							abcde
10103	Classroom	85.01		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Left							abcde
10104	Classroom	85.01		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Right							abcde
10104a	Resource	42.93		Horizontal	Daikin	UAVV9H10	30,000	1.50	180-140	Right							abcde
10105	Classroom	76.60		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Left							abcde
10115	Tech Lab	76.68		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Left							abcde
10120	Admin Office	16.68	95.36	Vertical	Apollo	VUV-1600	28,000	1.40	180-140	Left	Right	N/A	Side	N/A	Right Left	300x250 300x250	fj
10120a	Copy Room	8.02															
10121	P Office	11.66															
10122	VP Office	11.34															
10125	Staff Room	35.14															
10125b	Office	12.52															

Daikin			Apollo		
UAVV9H10	UAVV9H13	UAVV9H15	VUV-1200	VUV-1600	VUV-2000
	1				
			1		
	1				
	1				
	1				
	1				
	1				
1					
1					
	1				
	1				
	1				
	1				
				1	
					1
		1			
	1				
	1				
	1				
	1				
	1				
			1		
					1
	1				
	1				
	1				
	1				
				1	



Unit Ventilator Data
Classroom Ventilation Program

Changes to original plan
Vertical Unit Ventilators

02-Jan-23

Room No.	Use	Room Area		Unit Ventilator								Top Plenum	Back/Side Plenum	Top Shroud	Duct Conn.		Notes	Daikin			Apollo													
				Type	Make	Model	BTUH	GPM	°F	Pipe Conn.	Hinge				Side	Size		UAVV9H10	UAVV9H13	UAVV9H15	VUV-1200	VUV-1600	VUV-2000											
10130	Library	152.00	170.16	Vertical	Apollo	VUV-2000	55,000	2.75	180-140	Right	Left	860	N/A	N/A	Left	350x300	f																	
10130a	L Office	18.16													Right	500x300						1												
10131	Classroom	76.46		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Left																								
10132	Classroom	84.89		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Left																								
10133	Classroom	76.46		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Left																								
10134	Classroom	84.96		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Left																								
10135	Classroom	76.46		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Left																								
10136	Classroom	76.14		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Left																								
10137	Classroom	76.46		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Left																								
Ferris																																		
10101	Staff Room	57.96	121.46	Vertical	Apollo	VUV-1600	55,000	2.75	180-140	Right	Left	N/A	Right Side	N/A	Left	560x160	fj					1												
10102	P Office	11.07																																
10103	Admin Office	34.49																																
10103a	VP Office	9.01																																
10104	A Circulation	8.93																																
10144	Computer	63.71		Horizontal	Daikin	UAVV9H13	55,000	2.75	180-140																									
10145	Resource	65.63		Horizontal	Daikin	UAVV9H13	55,000	2.75	180-140																									
10153	Band	69.25		Horizontal	Daikin	UAVV9H13	55,000	2.75	180-140																									
10154	Band	69.25		Horizontal	Daikin	UAVV9H13	55,000	2.75	180-140																									
10166	Resource	67.63		Horizontal	Daikin	UAVV9H13	55,000	2.75	180-140																									
10168	Classroom	82.94		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140																									
10173	Classroom	58.47		Horizontal	Daikin	UAVV9H13	55,000	2.75	180-140	Left																								
10174	Classroom	78.92		Horizontal	Daikin	UAVV9H13	55,000	2.75	180-140	Left																								
10175	Classroom	82.82		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Left																								
10188	Classroom	81.25		Horizontal	Daikin	UAVV9H13	55,000	2.75	180-140	Right																								
Garden City																																		
10101	Classroom	80.45		Horizontal	Daikin	UAVV9H13	55,000	2.75	180-140	Right																								
10102	Classroom	80.10		Horizontal	Daikin	UAVV9H13	55,000	2.75	180-140	Right																								
10103	Classroom	80.71		Horizontal	Daikin	UAVV9H13	55,000	2.75	180-140	Right																								
10104	Classroom	80.29		Horizontal	Daikin	UAVV9H13	55,000	2.75	180-140	Right																								
10107	Classroom	92.18		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Right																								
10110	Staff Room	57.76		Horizontal	Daikin	UAVV9H13	40,000	2.00	180-140	Left																								
10111	Classroom	92.18		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Right																								
10112	Classroom	92.18		Horizontal	Daikin	UAVV9H13	65,000	3.25	180-140	Right																								
10117	Resource	25.99	58.72	Vertical	Apollo	VUV-1200	30,000	1.50	180-140	Left	Left	N/A	Back	100	Left	150x150	fj																	
10122a	VP Office	9.69																																
10119	P Office	15.24																																
10120	Admin Office	33.79																																
10126	Resource	37.84																Right	400x300															
10143	Resource	43.42	Right																															
Gilmore																																		
10101	Classroom	76.54		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Left																								
10102	Classroom	85.13		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Left																								
10103	Psychologist	19.31	147.49	Vertical	Apollo	VUV-1600	25,000	1.25	180-140	Right	Right	N/A	Back	279	Right	400x250	f																	
10104	Conference	9.25																																
10105	Reception	21.13																																
10106	Itinerant	9.34																																
10107	Counselling	14.33																																
10110	Instruction	31.90																																
10111	Counselling	14.42																																
10112	Instruction	27.81																																
10109	Classroom	84.95	Left	350x250																														

Unit Ventilator Data
Classroom Ventilation Program

 Changes to original plan
 Vertical Unit Ventilators

02-Jan-23

Room		Room Area		Unit Ventilator							Top Plenum	Back/Side Plenum	Top Shroud	Duct Conn.		Notes	
No.	Use			Type	Make	Model	BTUH	GPM	°F	Pipe Conn.	Hinge				Side	Size	
10113	Classroom	84.95		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Left							abcde
10118	Resource	48.99		Horizontal	Daikin	UAVV9H10	28,000	3.00	180-140	Right							abcde
10121	Classroom	88.63		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Right							abcde
10122	Classroom	88.63		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Left							abcde
10123	Classroom	93.37		Horizontal	Daikin	UAVV9H13	60,000	2.75	180-140	Right							abcde
10124	Classroom	88.63		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Left							abcde
10125	Classroom	88.63		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Right							abcde
10132	P Office	15.98	88.48	Vertical	Apollo												
10134	Admin Office	59.27				VUV-1200	20,000	1.25	180-140	Left	Left	N/A	Back	N/A	Right	300x250	fj
10134a	VP Office	13.23													Left	350x250	

Daikin			Apollo		
UAVV9H10	UAVV9H13	UAVV9H15	VUV-1200	VUV-1600	VUV-2000
	1				
1					
	1				
	1				
	1				
	1				
	1				
			1		

Unit Ventilator Data
Classroom Ventilation Program

Changes to original plan
Vertical Unit Ventilators

02-Jan-23

Room No.	Use	Room Area	Unit Ventilator								Top Plenum	Back/Side Plenum	Top Shroud	Duct Conn.		Notes	Daikin			Apollo																	
			Type	Make	Model	BTUH	GPM	°F	Pipe Conn.	Hinge				Side	Size		UAVV9H10	UAVV9H13	UAVV9H15	VUV-1200	VUV-1600	VUV-2000															
10133	Copy Room	9.34	102.38	Vertical	Apollo	VUV-1200	60,000	3.00	180-140	Left	Right	840	Back	N/A	Right Left	200x150 400x350	f																				
10133a	Office	7.72																																			
10137	Staff Room	85.32																																			
10138	Classroom	76.54		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Left																											
10139	Classroom	79.24		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Left																											
10148	Classroom	85.49		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Left																											
10150	ESL	33.13	168.24	Vertical	Apollo	VUV-1600	30,000	1.50	180-140	Left	Right	710	Back	N/A	Left	500x400	f																				
10152	L Office	20.35																																			
10154	Library N	114.76																																			
	Library S	92.10		Horizontal	Daikin	UAVV9H15	60,000	3.00	180-140	Left																											
10153	Tech Lab	76.54		Horizontal	Daikin	UAVV9H13	50,000	2.50	180-140	Left																											
10156	Multipurpose	238.31		Vertical	Apollo	VUV-2000	30,000	1.50	180-140	Left	Left	710	Back	N/A	Left	500x400	f																				
10158	Resource	70.01		Horizontal	Daikin	UAVV9H13	55,000	2.75	180-140	Left																											
10158a	R Office	11.80																																			
10159	Resource	82.49		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Right																											
10160	Classroom	100.43		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Right																											
20102	Classroom	84.95		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Left																											
20103	Classroom	85.54		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Left																											
20104	Classroom	85.54		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Left																											
20105	Classroom	76.31		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Left																											
Grauer																																					
10114	Classroom	77.47		Horizontal	Daikin	UAVV9H13	55,000	2.75	180-140	Left																											
10116	Admin Office	33.79	59.27	Vertical	Apollo	VUV-1200	15,000	0.75	180-140	Left	Left	N/A	Back	305	Top	k	f																				
10117	P Office	17.87																																			
10118	Copy Room	7.61																																			
10121	Community	44.24		Horizontal	Daikin	UAVV9H10	15,000	0.75	180-140	Right																											
10125	Library	125.43		Horizontal	Daikin	UAVV9H13	30,000	1.50	180-140	Right																											
				Horizontal	Daikin	UAVV9H13	30,000	1.50	180-140	Right																											
10128	Strongstart	90.02		Horizontal	Daikin	UAVV9H13	55,000	2.75	180-140	Right																											
10129	Classroom	89.63		Horizontal	Daikin	UAVV9H13	55,000	2.75	180-140	Left																											
10130	Resource	66.73		Horizontal	Daikin	UAVV9H13	55,000	2.75	180-140	Right																											
10131	Resource	76.46		Horizontal	Daikin	UAVV9H13	55,000	2.75	180-140	Right																											
10133	Resource	32.72	120.88	Vertical	Apollo	VUV-1600	44,000	2.20	180-140	Right	Right	660	Back	N/A	Left Right	300x250 450x300	f																				
10133a	Office	12.28																																			
10138	Classroom	75.88																																			
10139	Classroom	74.91		Horizontal	Daikin	UAVV9H13	55,000	2.75	180-140	Left																											
10140	Multipurpose	136.56		Vertical	Apollo	VUV-1600	50,000	2.50	180-140	Left	Left	1450	Back	N/A	Left	560x300	f																				
10141	Classroom	73.94		Horizontal	Daikin	UAVV9H13	55,000	2.75	180-140	Left																											
10142	Classroom	73.94		Horizontal	Daikin	UAVV9H13	55,000	2.75	180-140	Right																											
10143	Classroom	73.55		Horizontal	Daikin	UAVV9H13	55,000	2.75	180-140	Left																											
10144	Classroom	73.55		Horizontal	Daikin	UAVV9H13	55,000	2.75	180-140	Right																											
Kidd																																					
10113	Classroom	76.02		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Left																											
10114	Classroom	76.35		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Left																											
10116	Classroom	76.02		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Left																											
10117	Classroom	76.02		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Right																											
10118	Classroom	85.20		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Right																											
10119	Resource	69.22		Horizontal	Daikin	UAVV9H13	45,000	2.25	180-140	Right																											
10123	A Circulation	9.49	46.24	Horizontal	Daikin	UAVV9H13	35,000	1.75	180-140	Right							abcde																				
10124	P Office	10.59																																			
10125	Admin Office	26.16																																			
10128	Staff Room	48.36		Horizontal	Daikin	UAVV9H10	35,000	1.75	180-140	Right																											



Unit Ventilator Data
Classroom Ventilation Program

Changes to original plan
Vertical Unit Ventilators

02-Jan-23

Room No.	Use	Room Area		Unit Ventilator								Top Plenum	Back/Side Plenum	Top Shroud	Duct Conn.		Notes	Daikin			Apollo																
				Type	Make	Model	BTUH	GPM	°F	Pipe Conn.	Hinge				Side	Size		UAVV9H10	UAVV9H13	UAVV9H15	VUV-1200	VUV-1600	VUV-2000														
10131	Library	145.21	159.86	Vertical	Apollo	VUV-1200	25,000	1.20	180-140	Right	Left	860		N/A	L	450x300	f																				
10131a	L Office	14.65		Vertical	Apollo	VUV-1200	25,000	1.20	180-140	Left	Left	860		N/A	R	450x300	f																				
10132	Classroom	84.08		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Left							abcde																				
10133	Classroom	75.74		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Left							abcde																				
10135	Classroom	88.34		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Left							abcde																				
10136	Classroom	88.53		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Right							abcde																				
10141	Classroom	87.82		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Left							abcde																				
10142	Resource	43.56	86.42	Vertical	Apollo	VUV-1200	30,000	1.50	180-140	Right	Left	860	Back	N/A	R	450x300	f																				
10142a	Resource	42.86		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Left								abcde																			
10143	Classroom	89.23		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Left							abcde																				
10144	Classroom	88.53		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Left							abcde																				
10146	Classroom	88.53		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Right							abcde																				
Lee																																					
10101	Classroom	82.52		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Left							abcde																				
10102	Classroom	85.16		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Left							abcde																				
10103	Classroom	83.23		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Left							abcde																				
10104	Classroom	84.45		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Left							abcde																				
10105	Classroom	75.23		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Left							abcde																				
10106	Classroom	84.88		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Left							abcde																				
10107	Classroom	83.78		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Left							abcde																				
10120	ESL	28.67	107.85	Vertical	Apollo	VUV-1600	28,000	1.40	180-140	Left/Right	Right	N/A	Back	N/A	L	350x250	fj																				
10121	Resource	25.68																																			
10127	Admin Office	32.94																																			
10128	VP Office	10.28																																			
10129	P Office	10.28																																			
10204	Resource	41.58	83.16	Vertical	Apollo	VUV-1200	28,000	1.40	180-140	Left/Right	Left	860	Back	N/A	L	450x300	f																				
10205	Resource	41.58																																			
10147	Classroom	80.33		Horizontal	Daikin	UAVV9H13	50,000	2.50	180-140	Left							abcde																				
10148	Classroom	81.04		Horizontal	Daikin	UAVV9H13	50,000	2.50	180-140	Left							abcde																				
10149	Classroom	81.04		Horizontal	Daikin	UAVV9H13	50,000	2.50	180-140	Left							abcde																				
10151	L Commons	79.68	211.63	Vertical	Apollo	VUV-2000	42,000	2.10	180-140	Right	Right	860	N/A	N/A	L	300x250	f																				
10152	Library	117.14																																			
15153	L Office	14.81																																			
20101	Classroom	80.33		Horizontal	Daikin	UAVV9H13	50,000	2.50	180-140	Left							abcde																				
20102	Classroom	81.15		Horizontal	Daikin	UAVV9H13	50,000	2.50	180-140	Left							abcde																				
20103	Classroom	81.15		Horizontal	Daikin	UAVV9H13	50,000	2.50	180-140	Left							abcde																				
McKay																																					
10101	Resource	76.69		Horizontal	Daikin	UAVV9H13	55,000	2.75	180-140	Left							abcde																				
10102	Resource	40.94		Horizontal	Daikin	UAVV9H10	25,000	1.25	180-140	Right							abcde																				
10104	Classroom	85.16		Horizontal	Daikin	UAVV9H15	55,000	2.75	180-140	Left							abcde																				
10118	Classroom	83.23		Horizontal	Daikin	UAVV9H13	55,000	2.75	180-140	Left							abcde																				
10123	Copy Room	6.69	100.75	Vertical	Apollo	VUV-1600	40,000	2.00	180-140	Left/Right	Left	N/A	N/A	N/A	R	450x300	fj																				
10126	Staff Room	45.53																																			
10128	VP Office	10.35																																			
10129	Admin Office	25.87																																			
10131	P Office	12.31																																			
10135	Classroom	85.13		Horizontal	Daikin	UAVV9H13	55,000	2.75	180-140	Left							abcde																				
10136	Classroom	76.31		Horizontal	Daikin	UAVV9H13	55,000	2.75	180-140	Left							abcde																				
10137	Classroom	84.95		Horizontal	Daikin	UAVV9H13	55,000	2.75	180-140	Left							abcde																				
10138	Classroom	76.49		Horizontal	Daikin	UAVV9H13	55,000	2.75	180-140	Left							abcde																				
10139	Classroom	85.26		Horizontal	Daikin	UAVV9H13	55,000	2.75	180-140	Left							abcde																				
10140	Classroom	85.26		Horizontal	Daikin	UAVV9H13	55,000	2.75	180-140	Left							abcde																				

Unit Ventilator Data
Classroom Ventilation Program

 Changes to original plan
 Vertical Unit Ventilators

02-Jan-23

Room No.	Use	Room Area		Unit Ventilator								Top Plenum	Back/Side Plenum	Top Shroud	Duct Conn.		Notes
				Type	Make	Model	BTUH	GPM	°F	Pipe Conn.	Hinge				Side	Size	
10141	Classroom	76.32		Horizontal	Daikin	UAVV9H13	55,000	2.75	180-140	Left							abcde
10143	Library	85.32		Horizontal	Daikin	UAVV9H13	55,000	2.75	180-140	Left							abcde
Mitchell																	
10143	Classroom	73.21		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Right							abcde
10144	Classroom	73.30		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Left							abcde
10147	Classroom	71.92		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Right							abcde
Steves																	
10108	Classroom	89.78		Horizontal	Daikin	UAVV9H13	55,000	2.75	180-140	Left							abcde
10109	Classroom	89.74		Horizontal	Daikin	UAVV9H13	55,000	2.75	180-140	Left							abcde
10110	Classroom	88.85		Horizontal	Daikin	UAVV9H13	55,000	2.75	180-140	Left							abcde
10115	Classroom	97.97		Horizontal	Daikin	UAVV9H13	55,000	2.75	180-140	Right							abcde
10116	Classroom	87.92		Horizontal	Daikin	UAVV9H13	55,000	2.75	180-140	Left							abcde
10117	Classroom	102.87		Horizontal	Daikin	UAVV9H13	55,000	2.75	180-140	Left							abcde
10119	Classroom	89.19		Horizontal	Daikin	UAVV9H13	55,000	2.75	180-140	Left							abcde
10124	Library	186.25		Vertical	Apollo	VUV-2000	90,000	4.50	180-140	Right	Right	1160	N/A	N/A	Top		f
10125	Classroom	87.60		Horizontal	Daikin	UAVV9H13	55,000	2.75	180-140	Right							abcde
10133	Resource	38.56	77.79	Vertical	Apollo	VUV-1200	35,000	1.75	180-140	Left	Left	710	Back	N/A			f
10134	Resource	39.23															
10134a	Classroom	78.90		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Left							abcde
10135	Tech Lab	68.15		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Left							abcde
10138	Classroom	69.50															
10139	Classroom	71.27															
10140	Multipurpose	71.22															
10141	Classroom	69.50															
10144	Resource	80.91		Horizontal	Daikin	UAVV9H13	55,000	2.75	180-140	Left							abcde
10149	Classroom	76.64		Horizontal	Daikin	UAVV9H13	55,000	2.75	180-140	Right							abcde
10150	Classroom	79.11		Horizontal	Daikin	UAVV9H13	60,000	3.00	180-140	Left							abcde

Daikin			Apollo		
UAVV9H10	UAVV9H13	UAVV9H15	VUV-1200	VUV-1600	VUV-2000
	1				
	1				
	1				
	1				
	1				
	1				
	1				
	1				
	1				
					1
	1				
			1		
	1				
	1				
	1				
	1				
	1				

