

SD38 Water Quality Program
Stage 3 Action Plan

Unitech Work
SD38 Plumbing Work
SD38 Operations Work

28-Dec-22

Code	School	Fixture	Test Results	Pass	Fail	Lot #	Action to be Taken	Comments	
0010	Boyd	CRS 15 Foods Room 10114 (109)	0.016		X	1613392	1,3,5		
		CRS 16 Foods Room 10114 (109)	0.0038	X			1,3,5		
		CRS 17 Foods Room 10114 (109)	0.0038	X			1,3,5		
		CRS 18 Foods Room 10114 (109)	0.0028	X			1,3,5		
0130	Cambie	KCS 202 South of Room D102	0.0067		X	1613398	3,5	Re-pipe only, newer faucet and stops	
0060	McNair	CRS 135 Teaching Kitchen 10036	0.008		X	1613384	2,3,5		
		CRS 139 Teaching Kitchen 10036	0.0091		X		2,3,5		
		CRS 140 Teaching Kitchen 10036	0.0035	X			3,5		New handwash station
		CRS 141 Teaching Kitchen 10036	0.0074		X		2,3,5		
		CRS 118 1 Foods Prep 10055	0.0036	X			6		Custodial to remove any "Need to Flush Before Use" stickers
0070	McRoberts	KCS 149 Concession Rm 10139	0.012		X	1613387	1,5	Replace the faucet set, tubing and re-test	
0080	Palmer	KS 93 Staffroom 10147	0.0016	X		1616171	6	Custodial to remove any "Need to Flush Before Use" stickers	
		KCS 79 Foods Room 120	0.038		X		1,3,5	Re-pipe whole room	
		KCS 80 Foods Room 120	0.002	X			1,3,5		
		KCS 81 Foods Room 120	0.0018	X			1,3,5		
		KCS 82 Roods Room 120	0.013		X		1,3,5		
		KCS 84 Foods Room 120	0.012		X		1,3,5		
		KCS 85 Foods Room 120	0.0042	X			2,3,5		
		KCS 72 Foods Room 119	0.018		X		1,3,5		Re-pipe whole room
		KCS 73 Foods Room 119	0.0059		X		1,3,5		
		KCS 74 Foods Room 119	0.0058		X		1,3,5		
		KCS 75 Foods Room 119	0.0054		X		1,3,5		
		KCS 76 Foods Room 119	0.0059		X		1,3,5		
		KCS 77 Foods Room 119	0.0043	X			1,3,5		
		KCS 78 Foods Room 119	0.0024	X			3,3,5		
0090	Richmond	CRS 122 Room 143	0.00031	X		1613409	6	Custodial to remove any "Need to Flush Before Use" stickers	
		CRS 123 Room 143	0.00085	X					
		CRS 4 Foods Room 203	0.00034	X					
0250	Cook	KCS 54 Kitchen 10156D	0.00087	X		1613402	6	Custodial to remove any "Need to Flush Before Use" stickers	
0280	Diefenbaker	KCS 26 Daycare 120	0.003	X		1613391	6	Custodial to remove any "Need to Flush Before Use" stickers	
		KCS 1 Staffroom 10106	0.0058		X		1,5	Replace the faucet set, tubing and re-test	
0310	Errington	KCS 2 Staff Room	0.0055		X	1613381	1,5	Replace the faucet set, tubing and re-test	
0320	Ferris	BFS Outside Room 10114	0.00003	X		1616178	6	Custodial to remove any "Need to Flush Before Use" stickers	
0330	Garden City	KCS 50 Kitchen 10137	0.013		X	1616179	1,3,5	Repipes, replace the two faucet sets and re-test	
0350	General Currie	KCS 13 Staff Room 106	0.0031	X		1613403	6	Custodial to remove any "Need to Flush Before Use" stickers	
0360	Gilmore	KCS 54 Kitchen 10145	0.0025	X		1616181	6	Custodial to remove any "Need to Flush Before Use" stickers	
		CRS 3 Room 24	0.0035	X			6	Custodial to remove any "Need to Flush Before Use" stickers	

Code	School	Fixture	Test Results	Pass	Fail	Lot #	Action to be Taken	Comments
0370	Grauer	KCS 20 Kitchen 10104	0.03		X	1616183	1,3,5	Repipe, replace the two faucet sets and re-test
		BFS 2 Outside Rm 206	0.00021	X			6	Custodial to remove any "Need to Flush Before Use" stickers
0395	Homma	KCS 41 Kitchen 10143 KG Rm	0.018		X	1616188	1,3,5	
0410	Kilgour	KCS 3 Kitchen 10102	0.0041	X		1616187	6	Custodial to remove any "Need to Flush Before Use" stickers
0420	Kingswood	KCS 46 Kitchen 10112	0.16		X	1616186	1,3,5	
0450	McKay	KCS 21 Kitchen 10115 off Gym	0.049		X	1616192	1,3,5	
		BFS 5 Hallway by Rm 114	0.0049	X			3,5	Repipe existing bottle fill station and re-test
0460	McKinney	CRS 47 Room 10167	0.0079		X	1613390	7	Custodial to apply "Not for Drinking" sticker next to the sink
0505	Sea Island	KCS 14 Gym Kitchen 10115	0.14		X	1613406	1,3,5	Piping may be under the stage
		S 1 Top of Stairs North	0.014		X		1,3,5	
0540	Thompson	KCS 45 Kitchen 10143	0.0086		X	1613401	3,5	Replace CW & DHW piping only
0550	Tomsett	KCS 3 Staffroom 10151	0.0081		X	1613399	4,5	Replace CW piping only
0580	Woodward	CRS 39 Multipurpose Rm 303	0.0052		X	1616190	3,5	Replace CW & DHW piping only
0590	Wowk	KCS 3 Kitchen KG Rm 10206	0.0054		X	1613389	1,5	
0600	School Board Office	BFS 22 Main flr Lobby 10100	0.0011	X		1613407	6	Custodial to remove any "Need to Flush Before Use" stickers
		KCS 6 Third flr Kitchen 30113	0.0015	X			6	Custodial to remove any "Need to Flush Before Use" stickers
		KCS 4 Fourth flr Kitchen 40119	0.0058		X		3,5	Replace CW & DHW piping only
		KCS 1 Fourth flr Kitchen 40110	0.0092		X		3,5	Replace CW & DHW piping only

Notes

- 1 Replace deckmount faucet and supply tubes with Delta 26C3143
- 2 Replace wallmount faucet and supply tubes with Delta 28C6423
- 3 Repipe DHW and CW piping with Wirsbo, including new stops
- 4 Repipe CW only piping with Wirsbo
- 5 Retest upon completion
- 6 No further action needed, including no further need to flush, remove all flushing stickers
- 7 No further action needed, including no further need to flush, add "Not for Drinking" sticker



SD38 Handwashing Sink Program

28-Dec-2022

List of Sites with No Sink in Classroom

School	Location	Solution	Status
Dixon Elementary	Classroom 4 10136	Plumb-in new wall-hung handwashing sink tied to sink in 10134	Plan Re-done
	Classroom 7 10133	Plumb-in new wall-hung handwashing sink tied to sink in 10131	
Errington Elementary	Classroom 102 10153	Plumb-in new community handwashing station in recess outside Classroom 10155 (former DF location)	Plan Done
	Classroom 113 10135	Construct recess in wall outside cloak areas of Classroom 10134 and plumb in new community sink tied to sink in 10134	
	Classroom 115 10137		
	Classroom 122 10139		
Gilmore Elementary	Classroom 11 10101	Plumb-in new community handwashing station in recess outside Classroom 10109 (former DF location)	Plan Done
	Classroom 22 20105	Use existing community sink outside Room 20102	Exclude from program
Kidd Elementary	Classroom 101 10113	Plumb-in new community handwashing station in recess outside Classroom 10114 (former DF location)	Plan Done
	Classroom 104 10116		
Lee Elementary	Classroom 7 10102	Plumb-in new wall-hung handwashing sink tied to sink in 10104	Plan Re-done
	Classroom 15 10210	Plumb-in new community handwashing station in recess outside Classroom 10132 (former DF location)	
	Classroom 16 10211		
	Resource 10204	Plumb-in new wall-hung handwashing sink tied to sink in 10205	
Maple Lane Elementary	Classroom 2 10101	Use sink in 10103	Exclude from program
	Resource 10109/10110	Use sink in 10108	
McKay Elementary	Classroom 103 10138	Cut-in new drop-in sink in existing cabinet tied to sink in 10136	Plan Re-done
	Classroom 105 10140	Plumb-in new wall-hung handwashing sink tied to sink in 10141	
	Multipurpose 112 10147	Use washroom	
Mitchell Elementary	Classroom 10143	Use sinks in 10154	Exclude from program
	Classroom 10144		
	Classroom 10147		
Quilchena Elementary	Classroom 8 10113	Install new cabinet and sink, connected to existing sewer and water in corridor. Carefully re & re new vinyl plan flooring	Plan Done
Thompson Elementary	Classroom 16 10132	Use sinks in 10136	Exclude from program
	Classroom 17 10130		
	Classroom 18 10133		
	Classroom 19 10131		
Westwind Elementary	Classroom 22 10177	Plumb-in new community handwashing station on wall outside Conference Room 10171 and across from Library (former DF location)	Plan Done
	Classroom 24 10176		
	Classroom 25 10174		
	ELL 3 10127	Optional	
Woodward Elementary	Classroom 107 10102	Plumb-in new wall-hung handwashing sink at south end of room, connected to sink in Classroom 10104 via radiator cabinet	Plan Done
	Computer 110 10143	Optional	Exclude from program